



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20152455 Date: January 17, 2017
Project Title: SUMMIT FAIR BUILDING E Applicant:
SHELL - H & M
Location: PROGRESSIVE ELECTRONICS INC
820 NW BLUE PKWY, LEES 6102 ARLINGTON AVE
SUMMIT, MO 64086 RAYTOWN, MO 64133
Type of Work: Primary: (816) 765-5750
Occupancy Group: M
Description: NEW RETAIL BUILDING
SHELL
Construction Type: Type IIB (Unprotected)
Map Page: 195A

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Rejected

1. Plans shall include entire shell building and tenant spaces. FACP to be located in the landlord room located behind the tenant spaces. Make reference to the Yaeger Architecture drawings for the location of the landlord room and additional future tenant spaces. Yaeger Architecture @ 913-742-8000
2. System must be able to communicate back to the Summit Fair's shopping centers main Fire alarm Panel located in building D 860 NW blue Parkway.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.