

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

January 18, 2017

NOORY CONSTRUCTION
816 OSAGE AVE
KANSAS CITY, KS 66105

Permit No: PRCOM20162403
Project Title: LAW OFFICE OF CAMRON HOORFAR
Project Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063
Parcel Number: 61410151200000000
Location: LEES SUMMIT TOWN OF LOT 20 BLK 9
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR NEW LAW OFFICE

structural repair permit: PRCOM20162474

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

POST THE NUMERIC ADDRESS OF 415 ON THE BUILDING IN A CONTRASTING COLOR TO THE BACKGROUND READABLE FROM THE ROADWAY (JEFFERSON ST.) (VERIFIED AT INSPECTION)

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

PROVIDE ONE 2A-10BC FIRE EXTINGUISHER FOR EACH LEVEL OF THE BUILDING.
(VERIFIED AT INSPECTION)

3. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

MOUNT THE FIRE EXTINGUISHERS ON A NORMAL PATH OF TRAVEL WITH THE TOP OF THE EXTINGUISHER NO HIGHER THAN 60" OFF FINISH FLOOR. (VERIFIED AT INSPECTION)

