

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162134, Public Works Infrastructure Permit - Commercial
HT SOLUTIONS

Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Coliform Test 2	Brice Lawson	Passed	Sunday, January 22, 2017
PW-Water Line - Thrust Restraint	Brice Lawson	Passed	Sunday, January 22, 2017
PW-Street - Surface Course	Brice Lawson	Passed	Sunday, January 22, 2017

Informational

1 Brice Lawson 11/23/2016 12:44 PM

Wil-Pav laid the surface asphalt on the parking lot. It appeared that the surface was being laid at the proper thickness and was properly compacted.

PW-Water Line - Coliform Test 1	Brice Lawson	Passed	Sunday, January 22, 2017
---------------------------------	--------------	--------	--------------------------

Informational

1 Brice Lawson 01/19/2017 4:27 PM

The first bacterial sample was taken to the lab this morning at 9:00 a.m.

Comments:

