

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Failed	Monday, January 23, 2017
Partial Correction 1       Misc 1		OK TO COVER WITH BUILDING WRAP: SOUTH ELEVATION; WEST ELEVATION;  HIGH PERCENTAGE OF OVER-DRIVEN NAILS -- TO BE CORRECTED ON SUBSEQUENT WORK.	
Corrective Action Required 2       Misc 1		<b>CORRECTIONS POINTED OUT TO BE MADE ON WALL SHEATHING AT NORTH SIDE OF BUILDING</b>	

**Comments:**