

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161177, Building Permit - Commercial  
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Monday, January 23, 2017

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM BETWEEN POINTS HAND-NUMBERED ON PERMIT PRINTS: FROM (1) C/W TO (2); **FROM (1) CC/W TO (3) TO (4), WITH UFER GROUND JUMPER IN PLACE AT NW WALL; TWO INTERIOR GRADE BEAMS INTERSECTING WALL ON LINE (1) TO (4)**

Partial Correction  
2 Misc 1

**OK TO POUR WHEN READY ISOLATED FOOTINGS THROUGHOUT**

**Comments:**