

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, January 24, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS:
ONE-SIDING OF ELECT[115]; VEST [118] N WALL TWO LAYERS S FACE; TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK; MECH [145]; WOMENS RR [103]; MEN'S RR[104]; JANITOR [105]; FAMILY RR [106]; ELECT [115] SOUTH WALL SOUTH FACE; 102; 129; 144; 114 NORTH WALL; [116] S/SW WALLS; PLATFORM [117] EAST, SOUTH & NORTH WALLS;

SOUTH WALL OF E-W LEG OF N END OF CORR [128]; [131]-[143]; [145]; [147]-[150]; [157]; [151] THROUGH [156];

IN-WALL OK FOR: SANCTUARY 113 STARTING FROM PLATFORM (117) STAIR ALL THE WAY AROUND TO THE OTHER SIDE; RM 107 TO 112; DOUBLE STUD WALL BETWEEN 113&102; CORRIDOR [128]; [120] - [127];

Above Ceiling Inspection	John Borns	Partial	Tuesday, January 24, 2017
---------------------------------	------------	---------	---------------------------

Partial Correction
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: [132]; [135]; [139]; [142]; [146]; [155]; [156];

Partial Correction
2 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @: 130; 131; 133; 134; 136; 138; 141;

143; 145; 147; 149; 152; 153;

**Rough Framing
Inspection -
Commercial**

John Borns

Partial

Tuesday, January 24, 2017

Partial Correction

1 Misc 1

OK TO COVER WHEN READY L.G. STEEL FURRING FRAMING PER WALL SECTION 1/E1 ON ERECTION DRWG. TAPCON FASTENING APPROVED PER DETAIL 4/S4.01.

Partial Correction

2 Misc 1

OK TO COVER WHEN READY FRAMING ONLY AT: SOUTH WALL OF 120 OK FOR CONSTRUCTION OF ADJACENT RAMP; RAISED FLOOR FRAMING AT 121-127; SAME AT 120; FRAMING OF PLATFORM AT [128]; 7" HIGH PLATFORMS @ 137 & 140; **RAMP AT [128] N; STAIR AT [118] FRAMED FOR 7" RISERS; PLATFORMS FOR BOOTHS IN [137] & [140];**

Comments: