

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160984, Building Permit - Residential
Address: 3341 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, January 24, 2017

Corrective Action Required

1	Misc 1	-2x10 HEADERS SUPPORTING ROOF AND CEILING EAST WALL ARE OVERSPAN, HAVE ENGINEER ADDRESS. -STRAP GARAGE PORTAL. (straps are required to go from double top plate to the stud under the header) okay to insulate
---	--------	--

Comments: