

CODES ADMINISTRATION

Temporary Certificate of Occupancy

| Permit #: | PRCOM20160414 |
|-------------------------|--|
| Address: | 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081 |
| Inspected On: | Wednesday, January 25, 2017 |
| Inspected By: | Mike Copeland |
| Expiration Date: | 4/25/2017 12:00:00 AM |

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|--|---------------|------------------|--------------------------------|
| Occupancy Inspection - Codes Commercial | Mike Copeland | Temporary C of O | Wednesday, January 25, 2017 |

Corrective Action Required:

 1
 Misc 1
 -RETURN HANDRAIL TO GUARD

 -PROVIDE FIRE DEPARTMENT WITH A KNOX BOX

 -OBTAIN PLANNING APPROVAL

 -OBTAIN ENGINEERING APPPROVAL FOR SITE