



19 January 2017

TO: Joe Frogge
City of Lee's Summit
Codes Administration
220 SE Green St.
Lee's Summit, MO 64063

RE: Natural Way Chiropractic 1186 NE Douglas St Permit No. PRCOM20170076

Building Plan Review

- 1. 2012 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Provide accessible portion of counter at reception desk. Minimum 36" wide and maximum 36" tall.

RESPONSE: Existing reception counter meets above set parameters.

Thank you.

Erin Bardon

