

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Wednesday, January 25, 2017

Partial Correction  
1 Misc 1

**OK TO PRE-ROCK SHOWER WALLS/CHASES/LIDS AT: [108];  
[109]; [115]; [118];**

<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Wednesday, January 25, 2017
--	------------	---------	-----------------------------

Partial Correction  
1 Misc 1

**OK TO COVER EXTERIOR WALLS WITH BUILDING WRAP: ALL  
ELEVATIONS FULL HEIGHT**

HIGH PERCENTAGE OF OVER-DRIVEN NAILS -- TO BE CORRECTED  
ON SUBSEQUENT BUILDINGS.

**Comments:**