

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160868, Building Permit - Residential
Address: 257 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Thursday, January 26, 2017

All Rough Inspection - Residential	Mike Copeland	Failed	Thursday, January 26, 2017
---	---------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-NAIL EXTERIOR CORNER STUDS 12" -VENT KITCHEN SINK -NORTH END OF I BEAM REAR LIVIING ROOM, PROVIDE BEARING THE FULL WIDTH OF THE BEAM. SOLID BLOCK THE FULL WIDTH IN THE BASEMENT AT THE BEARING LOCATION. -STRAP TOP PLATE OVER HEADER REAR MASTER BED WALL. -PROVIDE FLOOR JOIST LAYOUT -NAIL PROTECTION ELECTRICAL AT STAIR WALL
---	--------	--

Comments: