

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, January 26, 2017

Partial Correction
1 Misc 1

LIGHT-GAUGE STEEL EXTERIOR WALL FRAMING SUBSTANTIALLY
COMPLETE WITH NO ISSUES FOUND AT: NORTH ELEVATION;
WEST ELEVATION; SOUTH ELEVATION;

Partial Correction
2 Misc 1

AREA SEPARATION WALL ON (7): **ABOVE ROOF EAST FACE OK TO
COVER WHEN READY EXCEPT A/E CLARIFICATION REQUIRED RE
DEFLECTION CLIP SCREWS AT LOCATIONS WITH
NON-STRUCTURAL HEADERS BELOW**

Comments: