

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161426, Building Permit - Commercial
Address: 720 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Thursday, January 26, 2017

**Comments: SECONDARY ELECTRICAL CONDUIT FROM TRANSFORMER LOCATION TO BUILDING ENTRY
OK TO COVER WHEN READY AFTER UNSUPPORTED PORTIONS OF CONDUIT ARE BEDDED WITH
CRUSHED ROCK.**