

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20163150, Building Permit - Commercial
Address: 48 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection -	John Borns	Not Ready	Friday, January 27, 2017
Codes Commercial			

Corrective Action Required

1 Misc 1

FIRE DEPARTMENT APPROVAL REQUIRED

Corrective Action Required

2 Misc 1

AFFIX PERMANENT ADDRESS LABEL TO ELECTRICAL SERVICE EQUIPMENT

Corrective Action Required

3 Misc 1

ELECT RECEPTS AT RR'S INOP

Corrective Action Required

4 Misc 1

ACCESSIBLE RESTROOM SIGNS TO BE MOUNTED ON DOORS

Corrective Action Required

5 Misc 1

BREAKTHROUGH OPENING @ SE CORNER PROPOSED TO BE ADDED TO PERMIT SCOPE. A/E REVISION REQUIRED.

Corrective Action Required

6 Misc 1

OK TO MOVE IN OFFICE FURNITURE. ELECT RECEPTS AT DEMOUNTABLE PARTITIONS SUBJECT TO TEST/APPROVAL WHEN INSTALLED.

Comments: