

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162364, Building Permit - Commercial
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, January 27, 2017

Partial Correction
1 Misc 1

NO ISSUES FOUND WITH LOWER LIFT UNDER-SLAB ELECTRICAL
CONDUIT FROM CENTER OF BLDG : ONE 1-1/4" PVC EAST TO
UNDER FOOTING; ONE 3/4" + TWO 1-1/4" + THREE 4" PVC WEST
TO UNDER FOOTING

Comments: