

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20161966, Building Permit - Residential
Address: 312 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Friday, January 27, 2017

Corrective Action Required

1	Misc 1	-FIREBLOCK BASEMENT THROUGHOUT PER CODE -BLOCK FLOOR JOISTS PER LAYOUT -INSTALL SECURITY BLOCKING BOTH REAR DOORS. -DECK 6x6 POSTS, PLANS CALL FOR CONTINUOUS POST, HAVE ENGINEER ADDRESS. -BOTH DOUBLE END JOSITS ON DECK HAVE NO BEARING OR HANGER.
---	--------	---

Comments: