

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162545, Building Permit - Residential
Address: 1357 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, January 30, 2017

Corrective Action Required

1	Misc 1	-AT ALL EXTERIOR AND INTERIOR BEARING WALL WHERE WALL TOP PLATES ARE BORED MORE THAN 50%, SHALL INSTALL STRUCTURAL STRAPS AND NAIL ALL STARP NAIL HOLES
---	--------	---

****OK TO INSULATE**

Comments: