

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162583, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, January 30, 2017

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING +  
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 1C216; 1C133;  
C137; [1D25]; **1C217; 1C218A; 1C219;**  
**1C218 WEST 1/2; REMOVE ABANDONED F.P. PIPING FROM EAST  
1/2 >> REQUEST RE-INSPECTION**

**1C221 & 1C223 OK TO COVER AFTER LOW-VOLTAGE WIRING IS  
COMPLETED WITH BOXES CLOSED**

**1D24 NOT APPROVED TO COVER**

**Comments:**