

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|---|--------------------------|
| Rough Framing Inspection - Commercial | John Borns | Partial | Monday, January 30, 2017 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY L.G. STEEL FURRING FRAMING PER WALL SECTION 1/E1 ON ERECTION DRWG. TAPCON FASTENING APPROVED PER DETAIL 4/S4.01. | |
| Partial Correction 2 Misc 1 | | OK TO COVER WHEN READY FRAMING ONLY AT: SOUTH WALL OF 120 OK FOR CONSTRUCTION OF ADJACENT RAMP; RAISED FLOOR FRAMING AT 121-127; SAME AT 120; FRAMING OF PLATFORM AT [128]; 7" HIGH PLATFORMS @ 137 & 140; RAMP AT [128] N; STAIR AT [118] FRAMED FOR 7" RISERS; PLATFORMS FOR BOOTHS IN [137] & [140]; [116]; RAISED FLOOR FOR [116] AND FOR BOOTH AT [151] SOUTH, WITH UNDER-FLOOR ELECTRICAL; | |
| In-wall Inspection | John Borns | Partial | Monday, January 30, 2017 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: ONE-SIDING OF ELECT[115]; VEST [118] N WALL TWO LAYERS S FACE; TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK; MECH [145]; WOMENS RR [103]; MEN'S RR[104]; JANITOR [105]; FAMILY RR [106]; ELECT [115] SOUTH WALL SOUTH FACE; 102; 129; 144; 114 NORTH WALL; [116] S/SW WALLS; PLATFORM [117] EAST, SOUTH & NORTH WALLS; SOUTH WALL OF E-W LEG OF N END OF CORR [128]; [131]-[143]; | |

[145]; [147]-[150]; [157]; [151] THROUGH [156];

IN-WALL OK FOR: SANCTUARY 113 STARTING FROM PLATFORM
(117) STAIR ALL THE WAY AROUND TO THE OTHER SIDE; RM 107
TO 112; DOUBLE STUD WALL BETWEEN 113&102; CORRIDOR
[128]; [120] - [127]; **[116]; BOOTH AT [151] SOUTH;**

Comments: