

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, January 30, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY COMPONENTS OF RATED CEILING ASSEMBLY AT: CORRIDORS; 4TH FLOOR; 3RD FLOOR;	
Partial Correction 2 Misc 1		OK TO TAPE, MUD, AND FIRE-STOP WHEN READY RATED WALLS AND CEILINGS AT: 4TH FLOOR; 116; 3RD FLOOR INCLUDING ELECTRICAL ROOM & BACK OF HOUSE; 2ND FLOOR INCLUDING ELECTRICAL ROOM;	
Partial Correction 3 Misc 1		RESILIENT CHANNEL PER UL U522 OK TO COVER WHEN READY AT WALLS AND CEILINGS AT: 4TH FLOOR EXCEPT AT STAIRWELLS AND ROOMS 430 AND 432;	
Partial Correction 4 Misc 1		OK TO COVER WHEN READY COMPONENTS OF RATED WALL ASSEMBLY AT: ONE LAYER 5/8" TYPE C GWB PRE-ROCK FOR ELECTRICAL PANELS AT SPACES 316; 216; ENSURE MAX 1/8" MARGINS AT ELECT BOX CUT-OUTS.	
Partial Correction 5 Misc 1		ELEVATOR SHAFT 3 LAYERS 5/8" TYPE X GWB AT LID 1ST LAYER 5/8" TYPE X GWB AT N,E,S WALLS	
Partial Correction 6 Misc 1		OK TO COVER AT STAIRWELLS: 2 LAYERS 5/8" TYPE X GWB AT WALLS BOTH STAIRWELLS; RESILIENT FURRING + 5/8" TYPE X GWB AT LANDING CEILINGS	

Comments: