

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Tuesday, January 31, 2017

**Comments: OK TO POUR WHEN READY CHILLER PAD FOOTING AFTER;
- CORNER RE-BARS, OR LACK THEREOF, ARE APPROVED BY SPECIAL INSPECTOR
- NORTH END RE-BAR CAGE IS RAISED FOR MIN 3" CLEARANCE
- ALL DEBRIS IS REMOVED FROM TRENCH**