

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20161966, Building Permit - Residential
Address: 312 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|---------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Tuesday, January 31, 2017 |

Corrective Action Required

| | | |
|---|--------|---|
| 1 | Misc 1 | <p>-FIREBLOCK BASEMENT THROUGHOUT PER CODE **FB ALL WALL SPACE FROM CEILING FURDOWN SPACE. ALL THE GAPS IN THE FIREBLOCKING SHEATHING MUST BE CLOSED WITH APPROVED FIREBLOCKING MATERIAL</p> <p>-BLOCK FLOOR JOISTS PER LAYOUT **OK HOW ARE YOU GOING TO INSULATE THE FLOOR NOW? INSULATE BEFORE BLOCKING</p> <p>-INSTALL SECURITY BLOCKING BOTH REAR DOORS. **BLOCK THE STUD 3 STUD SPACES OUT (OR TO CORNER OR WINDOW)</p> <p>-DECK 6x6 POSTS, PLANS CALL FOR CONTINUOUS POST, HAVE ENGINEER ADDRESS.</p> |
|---|--------|---|

Comments: