

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152455, Building Permit - Commercial  
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Tuesday, January 31, 2017
<b>Electrical Service Inspection - Commercial</b>	John Borns	Partial	Tuesday, January 31, 2017
Partial Correction 2            Misc 1		SERVICE RELEASED CONTINGENT ON G.E.C. BEING CAD-WELDED TO GROUND ROD PER APPROVED DRAWING	
<del><b>Footing Inspection - Commercial</b></del>	<del>John Borns</del>	<del>Not Ready</del>	Tuesday, January 31, 2017

**Comments: CHANGED WALL & FOOTING DESIGN REQUIRES SUBMISSION OF REVISED DRAWING. IF POUR, AT RISK.**