PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, February 01, 2017
Partial Correction			
1 Misc 1	OK TO COVER WHEN READY PVC UNDER-SLAB ELECTRICAL CONDUIT: ONE 3" + ONE 1" FROM ELEVATOR EQUIPMENT ROOM TO MDP LOCATION; LOWER LIFT CONDUIT COMPLETE AT MDP LOCATION;		
Concrete Walls and Columns Inspection	John Borns	Partial	Wednesday, February 01, 2017
Partial Correction			
1 Misc 1		OK TO POUR WHEN READY RETAINING WALL AT NORTH PER SECTION 6/S3.4;	

Comments: