

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162248, Building Permit - Residential
Address: 1353 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Failed	Thursday, February 02, 2017

Corrective Action Required
1 Misc 1

THE DECK PIERS THAT CARRY ROOF AND FLOOR LOAD ARE
ALREADY POURED. HAVE ENGINEER INSOECT AND APPROVED
THE PIERS. I INSPECTED AND OK THE TWO DECK LANDING PIERS

Comments: