

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, February 02, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: EAST WALL OF ELECT 3-161; OK TO 4' TOP-OUT WALLS; AREA "A"; AREA "C" COMPLETE EXCEPT C160;	
		ENSURE LEVEL-TO-LEVEL FLOOR OPENINGS ARE FIRESTOPPED BEFORE COVERING WALLS	
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, February 02, 2017
Partial Correction 1 Misc 1		LIGHT-GAUGE STEEL EXTERIOR WALL FRAMING SUBSTANTIALLY COMPLETE WITH NO ISSUES FOUND AT: NORTH ELEVATION; WEST ELEVATION; SOUTH ELEVATION; EAST ELEVATION	
Partial Correction 2 Misc 1		AREA SEPARATION WALL ON (7): ABOVE ROOF EAST FACE -- DEFLECTION CLIP SCREWS VERIFIED	
Miscellaneous Inspection	John Borns	Chiller Slab Pour Prep Passed	Thursday, February 02, 2017

Comments:

