

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Coliform Test 2	Brice Lawson	Passed	Friday, February 03, 2017

Informational

1 Brice Lawson 02/02/2017 9:22 AM

The 2nd day sample was taken at 9:13 a.m. This sample was taken from the cap tap at the 6" gate valve. This sample is for the 8" water main that was installed from the 12" water main to this 6" gate valve that is connected to the 8" by 8" by 6" tee fitting.

Informational

2 Brice Lawson 02/03/2017 1:46 PM

The second day samples for the 8" water main passed.

Comments: