

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, February 03, 2017

Partial Correction
1 Misc 1

OK TO INSTALL TYPE X DRYWALL AT PRE-ROCK SHOWER WALLS
AT:B106; 108; 109; 111; 113; 114; 115; B206; 208; 209; 211; 213;
214; 215;

ENSURE SPECIAL INSPECTOR HAS APPROVED HOLD-DOWN
HARDWARE INSTALLATION BEFORE COVERING ABOVE WALLS

Partial Correction
2 Misc 1

**OK TO COVER CEILING AND WALL CAVITIES AT 1ST FLOOR:
B106 WALLS; CEILING EXCEPT AT BR
B108 WALLS; CEILING EXCEPT AT BR
B114 CEILING ONLY EXCLUDING BR**

Comments: