

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162583, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, February 06, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 1C216; 1C133;
C137; [1D25]; 1C217; 1C218A; 1C219; 1C221; 1C223; 1C218
INCLUDING EAST 1/2; 1D24; **1D26 AFTER RATED WALL STICKERS
ARE ADHERED TO WALL RATHER THAN TO M/E/P
COMPONENTS; 1C117-1C120 SUBJECT TO RE-INSPECTION AFTER
RENOVATION PROCEEDS;**

Comments: