

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Monday, February 06, 2017
Partial Correction 2 Misc 1		OK TO COVER CEILING AND WALL CAVITIES AT 1ST FLOOR: B106; B108; B113; B114; B115; EXCLUDING CEILINGS AT BATHROOMS & WALLS AT SHOWERS	
Gas Piping Inspection - Commercial	John Borns	Partial	Monday, February 06, 2017
Partial Correction 1 Misc 1		GAS FEEDER LINE TRENCHED, LAID, AND BACKFILLED FROM PRINT MARK (G1) TO (G2); TRACER WIRE IN PLACE	

Comments: