

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170094, Building Permit - Residential  
Address: 400 SE WEISS CIR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Residential</b>	Mike Copeland	Failed	Tuesday, February 07, 2017

Corrective Action Required

1 Misc 1

SPOT CHECKED STEEL IN FOUNDATION WALL, NONE OF THE  
STEEL HAS BEEN TIED OFF.  
DO NOT POUR UNTIL INSPECTED AND APPROVED.

STOP WORK ISSUED OTHER THAN CORRECTING THE VIOLATION.

**Comments:**