

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Construction Taps Removed	Brice Lawson	Passed	Tuesday, February 07, 2017

Informational

- 1 Brice Lawson 02/07/2017 12:15 PM  
She Digs It removed the construction tap saddle and installed a stainless steel repair clamp. This tap is located on the 8" water main near the 8" gate valve where this 8" line tied into the 12" existing main.

This line was flushed for approx. 10 minutes to get any possible air out of the line.

The 8" valve at the tie-in to the 12" water main has been opened.

**Comments:**