

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20163122, Building Permit - Residential
Address: 504 NE CHIPMAN RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	John Borns	Passed	Tuesday, February 07, 2017
Final Electrical Inspection - Residential	John Borns	Passed	Tuesday, February 07, 2017

Comments: ENTIRE METER BANK REPLACED AT SOUTH END OF BUILDING. NO ISSUES FOUND. NO INSPECTION ACCESS TO PANELBOARDS AT APARTMENT UNITS. RELEASE SERVICES. CLOSE PERMIT.