

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170094, Building Permit - Residential
Address: 400 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Residential	Mike Copeland	Failed	Wednesday, February 08, 2017

Corrective Action Required

1	Misc 1	Second Inspection, multiple areas with no steel overlap, several corners still not tied and no overlap. Do not pour. STOP WORK ISSUED OTHER THAN CORRECTING THE VIOLATION.
---	--------	--

Comments: