

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20170094  
**Address:** 400 SE WEISS CIR, LEES SUMMIT, MO 64063  
**Inspected On:**  
**Inspected By:**

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:                      Inspector:                      Outcome:                      Date:

**Comments: Foundation steel, multiple areas in the wall have no overlap and areas with no steel ties. Do not perform any work on this project other than correcting the violations noted in the foundation steel. Call for inspection when corrected.**