

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162363, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Wednesday, February 08, 2017

Partial Correction
1 Misc 1

**OK TO COVER WHEN READY DEEP UNDER-SLAB ELECTRICAL
CONDUIT FROM UNDER EAST FOOTING TO ELECTRICAL ROOM**

Underslab Plumbing Inspection - Commercial	John Borns	Passed	Wednesday, February 08, 2017
---	------------	--------	------------------------------

**Comments: UNDER-SLAB PLUMBING COMPLETE INCLUDING RADON COLLECTION PIPING SYSTEM
FOUND INSTALLED PER REVISION /1\ ON DRAWING SHEET 2.00.**