

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161426, Building Permit - Commercial  
Address: 720 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Thursday, February 09, 2017

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING +  
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: **MEN'S RR;**  
**WOMEN'S RR; L.P. CLO; CASH COUNT; ARCHERY;**

<b>Electrical Service Inspection - Commercial</b>	John Borns	Failed	Thursday, February 09, 2017
---	------------	--------	-----------------------------

Corrective Action Required  
1 Misc 1

**SERVICE CONDUCTOR SIZE AND COUNT NOT PER APPROVED  
DRAWINGS**

**Comments:**