

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170295, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Failed	Thursday, February 09, 2017

Corrective Action Required

1	Misc 1	-SECURE RECEPTACLE BOXES -PROTECT PANELS FROM DAMAGE -AT THE SERVICE: 1) INSTALL MAIN BONDING JUMPER FROM THE LOWER BUS BAR TO THE BUS BAR WHERE THE SERVICE GROUNDED CONDUCTOR IS CONNECTED TO. 2) PROTECT GEC
---	--------	---

Comments: