

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161426, Building Permit - Commercial
Address: 720 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Friday, February 10, 2017

Comments: ELECTRICAL ENGINEER AND LS PLAN REVIEWER HAVE APPROVED USE OF THREE SETS OF 300 KCM SERVICE CONDUCTORS IN LIEU OF TWO SETS OF 600 KCM. RELEASE ELECTRICAL SERVICE.