

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161058, Building Permit - Commercial
Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Failed	Friday, February 10, 2017

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	-PRIMARY CONDUITS FROM TRANSFORMER PAD TO BUILDING APPROVED -NORTH PARKING LIGHTING APPROVED -SOUTH PARKING LIGHTING APPROVED -WEST PARKING LIGHTING APPROVED -DUCT BANK FROM HARDENED ROOM TO WEST LOCATION APPROVED
---	----------------------------------	---

Partial Correction

2	THE FOLLOWING AREAS ARE APPROVED	NO ISSUES FOUND ON TRENCHED PVC ELECTRICAL CONDUIT: FROM GENERATOR LOCATION: ONE 1" N/NE TO L.P. AT N EDGE OF DETENTION POND; ONE 2" + THREE 1' NE TO J.B. @ GATE CONTROLLER; FIVE 1" NW TO FUEL PUMP LOCATION
---	----------------------------------	--

Corrective Action Required

3	Misc 1	LIGHT POLE BASE RE-BAR CAGES MUST BE SUSPENDED TO PROVIDE MINIMUM 3" CLEARANCE AT BOTTOM OF HOLE
---	--------	---

Underground Plumbing Inspection - Commercial	John Borns	Partial	Friday, February 10, 2017
---	------------	---------	---------------------------

Partial Correction

1	Misc 1	CONDUITS FOR PARKING LIGHTS: SOUTH AND NORTH BORDER LIGHTS APPROVED
---	--------	--

Partial Correction

2	Misc 1	EXCEPT FOR VENT PIPING YET TO BE INSTALLED OK TO COVER
---	--------	---

BOTH OIL/WATER SEPARATORS SET IN PLACE AND PIPED

Comments: