

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160868, Building Permit - Residential
Address: 257 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	John Borns	Passed	Friday, February 10, 2017

Comments: NO DRAWINGS FOUND AT SITE. IF SPECIFIED FOOTING DIAMETER IS <= 16" OK TO POUR TWO PIERS AFTER BOTTOMS ARE CLEANED OF LOOSE MATERIAL.