



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20160836	Date:	February 10, 2017
Project Title:	TWIN LAKES INSURANCE	Applicant:	
Location:	2641 NE MCBAIN DR, LEES SUMMIT, MO 64064		Kansas City CCTV & Security 337 South 291 Hwy Liberty, Mo. 64068
Type of Work:			
Occupancy Group:	B		
Description:	NEW OFFICE BUILDING FOUNDATION PERMIT - PRCOM20161018	Primary:	(855)452-2288
Construction Type:	Type VB (Unprotected)		
Map Page:	175R		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

**1. SYSTEM OVERVIEW OUTLINE:**

**FIRE ALARM MATRIX**

REMOVE SMOKE DETECTORS AND MANUAL PULLS FROM THE EXTERIOR HORN/STROBE COLUMN. THE ONLY THING TO ACTIVATE THE EXTERIOR HORN/STROBE WILL BE THE WATER FLOW SWITCH.

(VERIFIED AT INSPECTION)

2. 2012IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. ACCEPTANCE TESTING OF THE FIRE ALARM SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300

(INFROMATION PURPOSES)

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**