

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162583, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Friday, February 10, 2017

Partial Correction

1 Misc 1

SPACES OK FOR USE: 1D22 EKG/VASCULAR; 1C133; 1C216; 1C137;  
**1C101;**

Corrective Action Required

2 Misc 1

1C218; 1D25; 1D26; 1C1`22; 1C123:  
- ELECTRICAL PANEL NOT IDENTIFIED  
- CIRCUITS AT PANEL NOT IDENTIFIED  
- DISCONNECT NOT LABELED  
- ENSURE ALL ELECTRICAL RECEPTACLES HAVE YOKE SPACERS IF  
NEEDED AND ARE MOUNTED SOLID  
- COPPER DRAIN PIPES NOT SECURED ABOVE FLOOR SINK  
- ONE EMERGENCY RECEPTACLE NOT HOT FOR TEST

**Comments:**