

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20163072, Building Permit - Residential  
Address: 510 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Plumbing Inspection - Residential</b>	John Borns	Partial	Monday, February 13, 2017

Corrective Action Required

1	Misc 1	IPC 903; LSCO 7-408 PLUMBING VENT SYSTEM MUST BE EXTENDED THROUGH ROOF
---	--------	---

Corrective Action Required

2	Misc 1	PIPING AT WATER HEATER: - PROVIDE DOCUMENTATION THAT HOT SIDE TUBING IS LISTED FOR THE PURPOSE - TPR DOWN-PIPE DOES NOT EXTEND TO WITHIN 6" OF FLOOR
---	--------	---

**Comments:**