

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162811, Building Permit - Commercial
Address: 860 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Monday, February 13, 2017
Underslab Electrical Inspection - Commercial	John Borns	Passed	Monday, February 13, 2017

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC & C.I. SANITARY DRAIN, WASTE, & VENT
PIPING INCLUDING GREASE INTERCEPTOR VENT PIPING.**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

3/4' PVC UNDER-SLAB ELECTRICAL CONDUIT IN PLACE AT NORTH.