

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162567, Building Permit - Commercial  
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:                                | Inspector: | Outcome: | Date:                     |
|--|------------|----------|---------------------------|
| <b>Footing Inspection -<br/>Commercial</b> | John Borns | Partial  | Monday, February 13, 2017 |

Partial Correction  
1 Misc 1

CONTINGENT ON SPECIAL INSPECTION OK TO POUR WHEN  
READY FOOTINGS FOR NORTH AND **SOUTH** PLANTERS BEHIND  
CLUBHOUSE.

**ALSO TWO PIER FOOTINGS AT REAR AND ONE AT NW CORNER.  
PINS DRIVEN INTO BOTTOMS MUST NOT PENETRATE POUR. ALL  
MATS TO BE MINIMUM 3" CLEAR AT BOTTOMS.**

**Comments:**