

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, February 13, 2017

Partial Correction
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM BETWEEN POINTS HAND-NUMBERED ON PERMIT PRINTS: FROM (1) C/W TO (2); FROM (1) CC/W TO (3) TO (4), WITH UFER GROUND JUMPER IN PLACE AT NW WALL; TWO INTERIOR GRADE BEAMS INTERSECTING WALL ON LINE (1) TO (4); **GRADE BEAMS CONNECTING COMMONS TO BLDG "C" (DESIGN MODIFIED TO CONSTRUCT ALL GRADE BEAMS IN PLACE OF SOME FOOTINGS AND THICKENED SLABS)**

Partial Correction
2 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS THROUGHOUT

Comments: