

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162362, Building Permit - Commercial
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, February 13, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY PVC DATACOMM CONDUITS(TWO 4" + TWO 1-1/4" + ONE 2" ROLLPIPE) FROM BLDG ENTRY AT EAST MIDDLE THEN SE 10' FROM E WALL THEN SE TO NEAR SEWER MANHOLE JUST NE OF SIDEWALK TO BE CONSTRUCTED;

Comments: