PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - John Borns Partial Tuesday, February 14, 2017

Commercial

Partial Correction

1 Misc 1 OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING

AND CONCEALED SYSTEMS AT 1ST FLOOR SPACES: 106; 108; 109;

111; 113; 114; 115;

Partial Correction

2 Misc 1 OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING

AND CONCEALED SYSTEMS AT **2ND FLOOR** SPACES: 206; 208; 209

BA & CLO CLGS ONLY; 211; **213**; 214; 215;

Partial Correction

3 Misc 1 OK TO COVER WHEN READY WALL FRAMING, CEILING FRAMING

AND CONCEALED SYSTEMS AT 3RD FLOOR SPACES: SHOWER

WALLS /CHASES AT 306, 308, 309, 311, 314, 315;

Gas Piping Inspection - John Borns Partial Tuesday, February 14, 2017

Commercial

Partial Correction

1 Misc 1 GAS FEEDER LINE TRENCHED, LAID, AND BACKFILLED FROM

PRINT MARK (G1) TO (G2); COMPLETE EAST TO BLDG ENTRY AT NE CORNER. INFRASOURCE PRESSURE TEST WITNESSED AT 100 PSI STEADY FOR >10 MINUTES. FEEDER PIPING TO BUILDING OK

FOR USE.

TRACER WIRE IN PLACE

Comments: