

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161058, Building Permit - Commercial
Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|---------------|----------|----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underground Electrical Inspection - Commercial | Mike Copeland | Partial | Tuesday, February 14, 2017 |

Partial Correction

| | | |
|---|----------------------------------|---|
| 1 | THE FOLLOWING AREAS ARE APPROVED | -PRIMARY CONDUITS FROM TRANSFORMER PAD TO BUILDING APPROVED -NORTH PARKING LIGHTING APPROVED -SOUTH PARKING LIGHTING APPROVED -WEST PARKING LIGHTING APPROVED -DUCT BANK FROM HARDENED ROOM TO WEST LOCATION APPROVED |
|---|----------------------------------|---|

Partial Correction

| | | |
|---|----------------------------------|--|
| 2 | THE FOLLOWING AREAS ARE APPROVED | NO ISSUES FOUND ON TRENCHED PVC ELECTRICAL CONDUIT: FROM GENERATOR LOCATION: ONE 1" N/NE TO L.P. AT N EDGE OF DETENTION POND; ONE 2" + THREE 1' NE TO J.B. @ GATE CONTROLLER; FIVE 1" NW TO FUEL PUMP LOCATION |
|---|----------------------------------|--|

Partial Correction

| | | |
|---|--------|--|
| 3 | Misc 1 | OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #5; |
|---|--------|--|

Comments: